



**C&AFPS**

# COMMERCIAL & AVON FIRE PROTECTION SERVICES

23 Bateman Road  
Coleshill  
Birmingham, B46 1EU

Telephone: 01675 467921  
Mobile: 07976 220667  
Email: info@commercialandavonfire.com  
www.commercialandavonfire.com

ASHBY CASTLE LAWN TENNIS CLUB  
SOUTH STREET  
ASHBY DE LA ZOUCH  
LEICESTER  
LE65 1BQ

SERVICE AGREEMENT No. 1235

## Certificate of Maintenance

Model	Quantity	Model	Quantity	Model	Quantity
CO2	2	POWDER	1	WATER	2



## Fire Equipment

This certificate confirms that we have completed the maintenance service of your fire equipment listed above



DATE MARCH 2022 ENGINEER JAMIE HUGHES

### Monthly Inspections:

It is recommended in BS 5306 Part 3 that:

A regular inspection of all portable extinguishers, spare cartridges and replacement charges should be carried out by a responsible person at least monthly to ensure that appliances are in the correct location and have not been discharged or lost pressure where it is fitted with a pressure indicator or suffered obvious damage.